
## PAULY



Fotoelektrik Pauly GmbH, Wahrbrink 6, 59368 Werne, Germany, Tel +49 2389 40227-70, Fax +49 2389 40227-77, www.fotoelektrik-pauly.de

## Connection Regulations for Reflex Optic Head with Driver Stage (v)



## Attention:

\*Remove the bridge between terminal 20 and 21, if installed.

The receiver—connection—cable transmit <u>very low signal level</u>, so please observe the following instructions while installation:

- Max. length of connection cable between control unit and optic head: 40m
- connection cables may not be installed parallel to thyristor-control-cable or any other supply-cable.
- receiver-connection-cable may not be installed parallel to transmitter-connection-cable.

Please observe also the optic head data sheet.

531 HE (09.12 - 3331 28 18.03 6.11.98 tb) 6.07.02 tb)

The design and make of the devices and their electronics are intellectual property of the company "Fotoelektrik Pauly GmbH". Internal circuit diagrams can, for copyright reasons, not be given therefore. Subject to technical alterations. Errors excepted. The reprinting of this data sheet or the copying of extracts from it are allowed only with the approval of the "Fotoelektrik Pauly GmbH" and with an indication of the sources used. Infringements are punishable by law.